



NOTES:

- EXCAVATION: 350 MINIMUM DEPTH, OR AS REQUIRED. CONTRACTOR SHALL CONTACT THE CITY IMMEDIATELY IF UNSUITABLE OR UNSTABLE SUBGRADE IS ENCOUNTERED, SUCH AS EXCESSIVE TOPSOIL, SOFT SPOTS, AND/OR ORGANIC MATTER. METHODS AND/OR MATERIAL MUST BE APPROVED BY THE CITY PRIOR TO COMMENCING WITH WORK. SUBGRADE TO BE CONSOLIDATED AND TESTED TO 98% S.P.D. MIN. REMOVE EXCESS MATERIAL OFF-SITE UNLESS OTHERWISE DIRECTED BY THE CITY.
- GRANULAR BASE: 300 MIN. LAYER OF GRANULAR A OR 19 CRUSHER RUN COMPACTED TO 98% S.P.D. MIN.
- ASPHALT: 80 COMPACTED DEPTH OF HOT MIX HL8/3 ASPHALTIC CONCRETE.
- EDGE TREATMENT: ASPHALT EDGE TO BE 45 DEGREES, TAMPED TO FORM UNIFORMLY, SMOOTH, CLEAN EDGES, WITHOUT LATERAL DEVIATIONS. SOD TO MEET AND MATCH EXISTING GRADES, WITH SMOOTH TRANSITIONS AT A MAXIMUM SLOPE 4:1. ALL SEEDED AND/OR SODDED AREAS SHALL BE 25 BELOW THE FINISH ELEVATION OF ASPHALT.. REMOVE EXCESS TOPSOIL AND SOD AS DIRECTED.
- DRAINAGE: GRADE WALKWAY WITH A 2% SLOPE OR CROWN, OR AS DIRECTED ON SITE. PONDING WATER ON ASPHALT WALKWAYS WILL NOT BE ACCEPTED.
- SODDING: ALL DISTURBED AREAS SHALL BE SODDED (AND/OR SEEDED) OVER 300 TOPSOIL (LIGHTLY COMPACTED), MINIMUM WIDTH OF 900mm. REFER TO PLAN.

All dimensions are in millimetres unless otherwise noted.

City of Pickering		Engineering Services Department	
DRAWN P. HELGESEN	<b>ASPHALT WALKWAY</b>	REVISION NO.	1
APPROVED R. STARR		DATE	NOVEMBER 2019
DATE JUNE 2012		<b>P-612</b>	