



NOTES:

1. GARAGES TO BE SET BACK MIN. 0.60m FROM STREETLINE, EAVES MAY EXTEND INTO SETBACK BUT NOT ONTO R.O.W.
2. PUBLIC LANE LIGHTING TO BE PROVIDED.
3. MINIMUM VERTICAL SEPARATION BETWEEN SUB-DRAIN AND UTILITY DUCTS TO BE 0.5m UNLESS CONCRETE ENCASED.

All dimensions are in metres unless otherwise noted.

MINIMUM COVER	
GAS MAIN	0.9m
BELL TELEPHONE	0.6m
BELL CONDUIT	0.6m
HYDRO	0.6m
CABLE TELEVISION	0.6m
STORM SEWER	1.8m
RDC	1.8m
SANITARY SEWER	2.5m
WATERMAIN	1.8m

City of Pickering		Engineering Services Department	
DRAWN D. POLAK	<h2 style="margin: 0;">TYPICAL CROSS-SECTION</h2> <h3 style="margin: 0;">10.0m SLIP-LANE 6.5m PAVEMENT</h3>		REVISION NO.
APPROVED P. HELGESEN			DATE
DATE AUGUST 2019			P-742SE