

Pickering Fire Services Food Truck Checklist

Note* Deputy Chief Yoshida, Platoon Chief, and Dispatch to be notified of any hydrants being used for the event.

jyoshida@pickering.ca platoonchief@pickering.ca dispatchers@ajax.ca

1. Only TSSA approved gaseous fuel burning appliance are to be used. Documentation to be available on site for review.
2. Certified kitchen suppression systems are required for any cooking which produces grease laden vapours and inspected within 6 months of the event.
3. Cylinders containing compressed gas shall be protected against mechanical damage.
4. Cylinders containing compressed gas shall be stored to hold them securely in place
5. Unobstructed 5 metre wide access route to be maintained along Esplanade North and South between Glenanna Road and Valley Farm Road
6. Portable fire extinguishers
 - a. Portable fire extinguishers shall be provided at each occupancy and be properly rated for the hazard present. (Minimum Size 5lb ABC fire extinguisher and Class K - 2.5g wet chemical extinguisher, if frying)
 - b. Portable extinguishers shall be kept operable and fully charged.
 - c. Portable extinguishers shall be located so that they are easily seen and shall be accessible at all times.
 - d. Portable extinguishers in proximity to a fire hazard shall be located so as to be accessible without exposing the operator to undue risk.
 - e. Event staff must be familiar with the safe operation of portable fire extinguishers in their work area.
7. Bins containing solid fuel (e.g. wood) must be located a minimum of 1.2 meters from any heat producing appliance, such as a barbeque.
8. Hydrants shall be readily available and unobstructed for use at all times. (2 hydrants) At least a 3 metre clearance from food trucks.