

Ribfest Inspection Checklist

Vendor:	Contact:	Tel:
1	Only TSSA approved gaseous fuel burning appliance are to be used. Documentation to be available on site for review.	
2	Cylinders containing compressed gas shall be protected against mechanical damage. Cylinders containing compressed gas shall be stored to hold them securely in place	
3	Unobstructed 5 metre wide access route to be maintained along Esplanade South between Glennana and Valley Farm Rd	
4	<p>Portable fire extinguishers</p> <ul style="list-style-type: none"> (a) Portable fire extinguishers shall be provided at each occupancy and be properly rated for the hazard present. (b) Portable extinguishers shall be kept operable and fully charged. (c) Portable extinguishers shall be located so that they are easily seen and shall be accessible at all times. (d) Portable extinguishers in proximity to a fire hazard shall be located so as to be accessible without exposing the operator to undue risk. (e) Event staff must be familiar with the safe operation of portable fire extinguishers in their work area. 	
5	Bins containing solid fuel (e.g. wood) must be located a minimum of 1.2 meters from any heat producing appliance, such as a barbeque.	
6	Hydrants shall be readily available and unobstructed for use at all times. (2 hydrants)	
7	Event Emergency / Disaster plan	
8	Event Security / Operations Plan	